



Memo-Servicing & Technical Info

I.F.E.D.A. MEMBERS SERVICING/TECHNICAL ADVICE/ UPDATE

From: The National Office

Date: 22nd March 2005.

Number 28

SAFFIRE EXTINGUISHERS

DISPOSAL OF SAFFIRE FOAM, WATER ADDITIVE & ANTIFREEZE

Disposing of small amounts of Saffire EX-U-300 Foam, EX-S-300FF Water Additive and Freezol Antifreeze into the sewage system should not interfere with the water treatment facilities.

None of the above products are expected to be toxic and should not cause any harm to aquatic life.

However, it is recommended to use excess amounts of water to dilute these products when disposing by this method.

Disposing of large amounts of Foa, Water Additive and Antifreeze should be treated as chemical waste and disposed of according to local regulations.

SAFFIRE EXTINGUISHERS - USE OF ANTIFREEZE – EFFECTIVE ON FIRE RATING

Saffire extinguishers filled with 15% (or less) Freezol Antifreeze should have no effect on the fire ratings.

Larger volumes of Freezol Antifreeze may well effect the ratings.

IFEDA offer thanks to Mr Grahame Wrath, Saffire Products Ltd. for this information.

DISCLAIMER

The information, facts and opinions expressed in this document are believed to be correct in the light of information currently available, but they are not guaranteed and neither IFEDA nor its officers can accept any responsibility in respect of these contents or their implementation.

This document in its entirety is copyright © of The Independent Fire Engineering & Distributors Association and must not be copied or distributed by any means whatsoever without the prior permission of the Association