



Memo-Servicing & Technical Info

I.F.E.D.A. MEMBERS SERVICING/TECHNICAL ADVICE/ UPDATE

From: The National Office

Date: August 2008

Number 57

**Subject: ADR Extinguisher Requirements
(Update to technical memos 46 – 47)**

CUSTOMERS WITH VEHICLES CARRYING HAZARDOUS MATERIAL

The ADR Regulations states that vehicles carrying hazardous material with a mass of more than 7.5 tonnes must be equipped with a minimum total of 12kg ABC dry powder with at least 1 x 2kg in the cab and one with a minimum capacity of 6kg.

Vehicles with a mass of more than 3.5 tonnes and up to and including 7.5 tonnes must be equipped with a minimum total of 8kg ABC dry powder with at least 1 x 2kg in the cab and one with a minimum capacity of 6kg.

Vehicles with a mass of up to and including 3.5 tonnes must be equipped with a minimum total capacity of 4kg ABC dry powder (1 x 4kg in the cab is acceptable or 2 x 2kg).

The maintenance label on extinguishers fitted to vehicles carrying hazardous material **must** show the 'Next Service Due Date'.

DISCLAIMER

The information, facts and opinions expressed in this document are believed to be correct in the light of information currently available, but they are not guaranteed and neither IFEDA nor its officers can accept any responsibility in respect of these contents or their implementation.

This document in its entirety is copyright © of The Independent Fire Engineering & Distributors Association and must not be copied or distributed by any means whatsoever without the prior permission of the Association