

Memo-Servicing & Technical Info

From: The National Office

Date: Apr 2014

Number 84

OFFICIAL RECALL NOTICE

30th March 2012



Product Code: C0EX2P Description: Polished Aluminium Commander Range 2kg CO2 Extinguisher (as pictured above)

Checkfire would like to inform the Fire Extinguisher trade of a possible product failure (where the valve has ejected from the cylinder whilst under pressure). Investigation has proved that in two cases only the cylinder was not correctly dried internally after polishing and the moisture has caused oxidisation. The **batch in question has a manufacture date of 2011/03 and a serial number range of 3241 – 3746**. Where these extinguishers are identified please telephone Bruce Robins on 029 2086 8333 or email bruce@checkfire.co.uk and appropriate action will be taken. The units would have been supplied from w/c 9th May 2011.

No other batches were affected by this defect.

Signed

Bruce Robins

Partner

For an on behalf of **CHECKFIRE**

DIISCLAIMER

The information, facts and opinions expressed in this document are believed to be correct in the light of information available but they are not guaranteed. Neither IFEDA nor its officers can accept responsibility in respect of these contents or their implementation.

This is an IFEDA member service, which is for the use of IFEDA Members only and in this format is copyright of the Independent Fire Engineering & Distributors Association. It must not be copied, or passed to others.